Data sheet

6ES7414-5HM06-0AB0



SIMATIC S7-400H, CPU 414-5H, central processing unit for S7-400H and S7-400F/FH, 5 interfaces: 1x MPI/DP, 1x DP, 1x PN and 2 for sync modules, 4 MB memory (2 MB data/2 MB program),

| General information | |
|---|--------------------------------------|
| Product type designation | CPU 414-5H PN/DP |
| HW functional status | 1 |
| Firmware version | V6.0 |
| Product function | |
| Isochronous mode | No |
| Engineering with | |
| Programming package | As of STEP 7 V5.5 SP2 with HF1 |
| CiR - Configuration in RUN | |
| CiR synchronization time, basic load | 100 ms |
| CiR synchronization time, time per I/O byte | 0 µs |
| Supply voltage | |
| Rated value (DC) | Power supply via system power supply |
| Input current | |
| from backplane bus 5 V DC, typ. | 1.6 A |
| from backplane bus 5 V DC, max. | 1.9 A |
| from backplane bus 24 V DC, max. | 150 mA; 150 mA per DP interface |
| from interface 5 V DC, max. | 90 mA; At each DP interface |
| Power loss | |
| Power loss, typ. | 7.5 W |
| Memory | |
| Type of memory | other |
| Work memory | |
| integrated | 4 Mbyte |
| integrated (for program) | 2 Mbyte |
| integrated (for data) | 2 Mbyte |
| • expandable | No |
| Load memory | |
| expandable FEPROM | Yes; with Memory Card (FLASH) |
| expandable FEPROM, max. | 64 Mbyte |
| integrated RAM, max. | 512 kbyte |
| expandable RAM | Yes |
| expandable RAM, max. | 64 Mbyte |
| Backup | |
| • present | Yes |
| with battery | Yes; all data |
| without battery | No |
| Battery | |
| Backup battery | |
| Backup current, typ. | 180 μA; Valid up to 40°C |

| Backup current, max. | 1 000 μΑ |
|---|--|
| Backup time, max. | Dealt with in the module data manual with the secondary conditions and the factors of influence |
| Feeding of external backup voltage to CPU | 5 V DC to 15 V DC |
| CPU processing times | |
| for bit operations, typ. | 18.75 ns |
| for word operations, typ. | 18.75 ns |
| for fixed point arithmetic, typ. | 18.75 ns |
| for floating point arithmetic, typ. | 37.5 ns |
| CPU-blocks | |
| DB | |
| Number, max. | 6 000; Number range: 1 to 16000 |
| • Size, max. | 64 kbyte |
| FB | |
| Number, max. | 3 000; Number range: 0 to 7999 |
| • Size, max. | 64 kbyte |
| FC | |
| • Number, max. | 3 000; Number range: 0 to 7999 |
| • Size, max. | 64 kbyte |
| ОВ | |
| • Number, max. | see instruction list |
| • Size, max. | 64 kbyte |
| Number of free cycle OBs | 1; OB 1 |
| Number of time alarm OBs | 4; OB 10-13 |
| Number of delay alarm OBs | 4; OB 20-23 |
| Number of cyclic interrupt OBs | 4; OB 32-35 |
| Number of process alarm OBs | 4; OB 40-43 |
| Number of DPV1 alarm OBs | 3; OB 55-57 |
| Number of startup OBs | 2; OB 100, 102 |
| Number of asynchronous error OBs | 9; OB 80-88 |
| Number of synchronous error OBs | 2; OB 121, 122 |
| Nesting depth • per priority class | 24 |
| | 27 |
| additional within an error OR | 1 |
| additional within an error OB Counters, timers and their refentivity | 1 |
| Counters, timers and their retentivity | 1 |
| Counters, timers and their retentivity S7 counter | |
| Counters, timers and their retentivity S7 counter Number | 2 048 |
| Counters, timers and their retentivity S7 counter Number Retentivity | |
| Counters, timers and their retentivity S7 counter Number | 2 048 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable | 2 048 Yes |
| Counters, timers and their retentivity S7 counter • Number Retentivity — adjustable — lower limit | 2 048 Yes 0 |
| Counters, timers and their retentivity S7 counter • Number Retentivity — adjustable — lower limit — upper limit | 2 048 Yes 0 2 047 |
| Counters, timers and their retentivity S7 counter Number Retentivity adjustable lower limit upper limit preset | 2 048 Yes 0 2 047 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range | 2 048 Yes 0 2 047 Z 0 to Z 7 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit | 2 048 Yes 0 2 047 Z 0 to Z 7 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit — upper limit | 2 048 Yes 0 2 047 Z 0 to Z 7 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit — upper limit — upper limit | 2 048 Yes 0 2 047 Z 0 to Z 7 0 999 |
| Counters, timers and their retentivity S7 counter Number Retentivity adjustable lower limit upper limit preset Counting range lower limit upper limit upper limit preset Counting range present | 2 048 Yes 0 2 047 Z 0 to Z 7 0 999 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit — upper limit SEC counter Present Type Number S7 times | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number | 2 048 Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit — upper limit SIEC counter Present Type Number Number Retentivity | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit IEC counter present Type Number S7 times Number Retentivity — adjustable | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit IEC counter present Type Number S7 times Number Retentivity — adjustable — lower limit | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number Retentivity — adjustable — lower limit — upper limit — upper limit — upper limit | 2 048 Yes 0 2 047 Z 0 to Z 7 0 9999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit IEC counter • present • Type • Number S7 times • Number Retentivity — adjustable — lower limit — upper limit — preset | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 |
| Counters, timers and their retentivity S7 counter Number Retentivity - adjustable - lower limit - upper limit - preset Counting range - lower limit - upper limit IEC counter present Type Number S7 times Number Retentivity - adjustable - lower limit - upper limit - uppeset Time range | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 No times retentive |
| Counters, timers and their retentivity S7 counter Number Retentivity - adjustable - lower limit - upper limit - preset Counting range - lower limit - upper limit IEC counter present Type Number S7 times Number Retentivity - adjustable - lower limit - upper limit - upper limit - upper limit - upper limit - lower limit - upper limit - upper limit - upper limit - preset Time range - lower limit | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 No times retentive |
| Counters, timers and their retentivity S7 counter Number Retentivity — adjustable — lower limit — upper limit — preset Counting range — lower limit — upper limit IEC counter present Type Number S7 times Number Retentivity — adjustable — lower limit — upper limit — preset Time range — lower limit — upper limit — upper limit — upper limit — upper limit | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 No times retentive |
| Counters, timers and their retentivity S7 counter Number Retentivity - adjustable - lower limit - upper limit - preset Counting range - lower limit - upper limit IEC counter present Type Number S7 times Number Retentivity - adjustable - lower limit - upper limit - upper limit - upper limit - upper limit - lower limit - upper limit - upper limit - upper limit - preset Time range - lower limit | Yes 0 2 047 Z 0 to Z 7 0 999 Yes SFB Unlimited (limited only by RAM capacity) 2 048 Yes 0 2 047 No times retentive |

| • Type | SFB |
|---|---|
| Number | Unlimited (limited only by RAM capacity) |
| ata areas and their retentivity | |
| Retentive data area (incl. timers, counters, flags), max. | Total working and load memory (with backup battery) |
| Flag | |
| • Size, max. | 8 192 byte |
| Retentivity available | Yes |
| Retentivity preset | MB 0 to MB 15 |
| Number of clock memories | 8; in 1 memory byte |
| Local data | |
| adjustable, max. | 16 kbyte |
| • preset | 8 kbyte |
| Address area | |
| I/O address area | |
| • Inputs | 8 kbyte |
| • Outputs | 8 kbyte |
| Process image | A11. |
| Inputs, adjustable | 8 kbyte |
| Outputs, adjustable Inputs, default | 8 kbyte |
| Inputs, defaultOutputs, default | 256 byte 256 byte |
| | |
| consistent data, max. Access to consistent data in process image | 244 byte Yes |
| Subprocess images | 165 |
| Number of subprocess images, max. | 15 |
| Digital channels | 10 |
| • Inputs | 65 536 |
| — of which central | 65 536 |
| Outputs | 65 536 |
| — of which central | 65 536 |
| Analog channels | |
| • Inputs | 4 096 |
| — of which central | 4 096 |
| Outputs | 4 096 |
| — of which central | 4 096 |
| lardware configuration | |
| Number of expansion units, max. | 21 |
| connectable OPs | 63 |
| Multicomputing | No |
| Interface modules | |
| Number of connectable IMs (total), max. | 6 |
| Number of connectable IM 460s, max. | 6 |
| Number of connectable IM 463s, max. | 4; Single mode only |
| Number of DP masters | |
| • integrated | 2 10: CD 443 F Extended |
| via CP Mixed made IM + CP permitted | 10; CP 443-5 Extended |
| Mixed mode IM + CP permitted via interface module | No |
| via interface module Number of IO Controllers | 0 |
| • integrated | 1 |
| • via CP | 0 |
| Number of operable FMs and CPs (recommended) | |
| • FM | See manual Automation System S7-400H fault-tolerant systems. Limited by |
| · ··· | number of slots and number of connections |
| • CP, PtP | See manual Automation System S7-400H fault-tolerant systems. Limited by |
| PROFINIO 15" 15" | number of slots and number of connections |
| PROFIBUS and Ethernet CPs | 14; Of which max. 10 CP as DP master |
| Slots | |
| required slots | 2 |
| ime of day | |

| Hardware clock (real-time) | Yes |
|---|--|
| retentive and synchronizable | Yes |
| Resolution | 1 ms |
| Deviation per day (buffered), max. | 1.7 s; Power off |
| Deviation per day (unbuffered), max. | 8.6 s; Power on |
| Operating hours counter | |
| Number | 16 |
| Number/Number range | 0 to 15 |
| Range of values | SFCs 2, 3 and 4: 0 to 32767 hours SFC 101: 0 to 2^31 - 1 hours |
| Granularity | 1 h |
| retentive | Yes |
| Clock synchronization | |
| • supported | Yes |
| • to MPI, master | Yes |
| to MPI, slave | Yes |
| • to DP, master | Yes |
| • to DP, slave | Yes |
| • in AS, master | Yes |
| • in AS, slave | Yes |
| on Ethernet via NTP | Yes; As client |
| Time difference in system when synchronizing via | |
| • Ethernet, max. | 10 ms; Via NTP |
| ● MPI, max. | 200 ms |
| Interfaces | |
| Number of RS 485 interfaces | 2 |
| Number of other interfaces | 2; Fiber-optic interface |
| Optical interface | No |
| 1. Interface | |
| Interface type | MPI/PROFIBUS DP |
| Isolated | Yes |
| Interface types | |
| • RS 485 | Yes |
| Output current of the interface, max. | 150 mA |
| Protocols | |
| • MPI | Yes |
| PROFIBUS DP master | Yes |
| PROFIBUS DP slave | No |
| MPI | |
| Number of connections | 32; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 |
| Transmission rate, max. | 12 Mbit/s |
| Services | 12 IVIDIUS |
| — PG/OP communication | Yes |
| | Yes |
| Routing Global data communication | Yes No |
| | |
| — S7 basic communication | No You |
| — S7 communication | Yes |
| — S7 communication, as client | Yes |
| — S7 communication, as server | Yes |
| PROFIBUS DP master | 10: If a diagnostice reporter is used on the line the market of several |
| Number of connections, max. | 16; If a diagnostics repeater is used on the line, the number of connection resources on the line is reduced by 1 |
| Transmission rate, max. | 12 Mbit/s |
| Number of DP slaves, max. | 32 |
| Services | |
| — PG/OP communication | Yes |
| — Routing | Yes |
| Global data communication | No |
| — S7 basic communication | No |
| | |
| | |
| S7 basic communication S7 communication S7 communication, as client | Yes Yes |

| S7 communication, as server | Yes |
|---|---|
| — Equidistance | No |
| — Isochronous mode | No |
| — SYNC/FREEZE | No |
| Activation/deactivation of DP slaves | No |
| Direct data exchange (slave-to-slave communication) | No |
| — DPV1 | Yes |
| Address area | |
| — Inputs, max. | 2 kbyte |
| — Outputs, max. | 2 kbyte |
| User data per DP slave | |
| — User data per DP slave, max. | 244 byte |
| — Inputs, max. | 244 byte |
| — Outputs, max. | 244 byte |
| — Slots, max. | 244 |
| — per slot, max. | 128 byte |
| PROFIBUS DP slave | |
| Number of connections | No configuration of CPU as DP slave |
| 2. Interface | |
| Interface type | PROFINET |
| Isolated | Yes |
| automatic detection of transmission rate | Yes; Autosensing |
| Autonegotiation | Yes |
| Autocrossing | Yes |
| Change of IP address at runtime, supported | No |
| Number of connection resources | 64 |
| Interface types | |
| • RJ 45 (Ethernet) | Yes |
| Number of ports | 2 |
| integrated switch | Yes |
| Protocols | |
| PROFINET IO Controller | Yes |
| PROFINET IO Device | No |
| PROFINET CBA | No |
| PROFIBUS DP master | No |
| PROFIBUS DP slave | No |
| Open IE communication | Yes |
| Web server | No |
| Point-to-point connection | No |
| Media redundancy | Yes |
| PROFINET IO Controller | 165 |
| Transmission rate, max. | 100 Mbit/s |
| Services | TOO MINIUG |
| — PG/OP communication | Yes |
| — S7 communication | Yes |
| — Isochronous mode | No |
| Shared device | Yes; Single mode only |
| — Shared device — Prioritized startup | No |
| — Number of connectable IO Devices, max. | 256; In redundant mode via both interfaces |
| Number of connectable IO Devices, max. Number of connectable IO Devices for RT, max. | 256 256 |
| — number of conflectable to Devices for R1, max. — of which in line, max. | 256 |
| Of which in line, max. Activation/deactivation of IO Devices | No |
| | |
| IO Devices changing during operation (partner ports), supported | No |
| Device replacement without swap medium | Yes |
| — Send cycles | 250 μs, 500 μs, 1 ms, 2 ms, 4 ms |
| — Updating time | 250 µs to 512 ms, minimum value depends on the number of configured user data and the configured single or redundant mode |
| Address area | |
| — Inputs, max. | 8 kbyte |
| — Outputs, max. | 8 kbyte |

| Lloor data consistency (1999) | 1 024 byte |
|---|---|
| User data consistency, max. Open IE communication | 1 024 byte |
| Number of connections, max. | 62 |
| Local port numbers used at the system end | 0, 20, 21, 25, 102, 135, 161, 34962, 34963, 34964, 65532, 65533, 65534, 65535 |
| Keep-alive function, supported | Yes |
| 3. Interface | |
| Interface type | PROFIBUS DP |
| Number of connection resources | 16 |
| Interface types | |
| • RS 485 | Yes |
| Output current of the interface, max. | 150 mA |
| Protocols | |
| PROFIBUS DP master | Yes |
| PROFIBUS DP slave | No |
| PROFIBUS DP master | |
| Number of connections, max. | 16 |
| Transmission rate, max. | 12 Mbit/s |
| Number of DP slaves, max. | 96 |
| Services | |
| — PG/OP communication | Yes |
| — Routing | Yes |
| Global data communication | No |
| — S7 basic communication | No |
| — S7 communication | Yes |
| S7 communication, as client | Yes |
| — S7 communication, as server | Yes |
| — Equidistance | No |
| — Isochronous mode | No |
| — SYNC/FREEZE | No |
| Activation/deactivation of DP slaves | No |
| Direct data exchange (slave-to-slave communication) | No |
| — DPV0 | Yes |
| — DPV1 | Yes |
| Address area | |
| — Inputs, max. | 6 kbyte |
| — Outputs, max. | 6 kbyte |
| User data per DP slave | |
| — User data per DP slave, max. | 244 byte |
| — Inputs, max. | 244 byte |
| — Outputs, max. | 244 byte |
| — Slots, max. | 244 |
| — per slot, max. | 128 byte |
| 4. Interface | |
| Interface type | Pluggable synchronization submodule (FO) |
| Plug-in interface modules | Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960-1AB06-0XA0 |
| 5. Interface | |
| Interface type | Pluggable synchronization submodule (FO) |
| Plug-in interface modules | Synchronization modules 6ES7960-1AA06-0XA0 or 6ES7960-1AB06-0XA0 |
| Protocols | |
| Redundancy mode | |
| Media redundancy | |
| Switchover time on line break, typ. | 200 ms |
| Number of stations in the ring, max. | 50 |
| SIMATIC communication | |
| S7 routing | Yes |
| Open IE communication | |
| • TCP/IP | Yes; via integrated PROFINET interface and loadable FBs |
| Number of connections, max. | 62 |
| — Data length, max. | 32 kbyte |
| | |

| several passive connections per port, supported | Yes |
|---|--|
| • ISO-on-TCP (RFC1006) | Yes; Via integrated PROFINET interface or CP 443-1 and loadable FBs |
| Number of connections, max. | 62 |
| — Data length, max. | 32 kbyte; 1 452 bytes via CP 443-1 Adv. |
| • UDP | Yes; via integrated PROFINET interface and loadable FBs |
| Number of connections, max. | 62 |
| — Data length, max. | 1 472 byte |
| Web server | |
| supported | No |
| Isochronous mode | |
| Equidistance | No |
| communication functions / header | |
| PG/OP communication | Yes |
| Number of connectable OPs without message processing | 63 |
| Number of connectable OPs with message processing | 63; When using Alarm_S/SQ and Alarm_D/DQ |
| Data record routing | Yes |
| Global data communication | |
| supported | No |
| S7 basic communication | |
| supported | No |
| S7 communication | |
| • supported | Yes |
| as server | Yes |
| as client | Yes |
| User data per job, max. | 64 kbyte |
| User data per job (of which consistent), max. | 462 byte; 1 variable |
| S5 compatible communication | 102 syco, 1 valuatio |
| • supported | Yes; (via CP max. 10 and FC AG_SEND and FC AG_RECV) |
| User data per job, max. | 8 kbyte |
| User data per job (of which consistent), max. | 240 byte |
| Number of simultaneous AG-SEND/AG-RECV orders per | 64/64 |
| CPU, max. | V-1/0-1 |
| Standard communication (FMS) | |
| • supported | Yes; Via CP and loadable FB |
| Number of connections | |
| • overall | 64 |
| usable for PG communication | |
| reserved for PG communication | 1 |
| adjustable for PG communication, max. | 0 |
| usable for OP communication | |
| reserved for OP communication | 1 |
| — adjustable for OP communication, max. | 0 |
| usable for S7 basic communication | |
| reserved for S7 basic communication | 0 |
| — adjustable for S7 basic communication, max. | 0 |
| usable for S7 communication | |
| — reserved for S7 communication | 0 |
| — adjustable for S7 communication, max. | 0 |
| usable for routing | |
| — reserved for routing | 0 |
| — adjustable for routing, max. | 0 |
| S7 message functions | |
| Number of login stations for message functions, max. | 63; Max. 63 with Alarm_S/SQ and Alarm_D/DQ (OPs); max. 8 with Alarm, Alarm_8, Alarm_8P, Notify and Notify_8 (e.g. WinCC) |
| Symbol-related messages | No |
| SCAN procedure | No |
| Program alarms | Yes |
| Process diagnostic messages | Yes |
| simultaneously active Alarm-S blocks, max. | 400; Simultaneously active alarm_S/SQ blocks or alarm_D/DQ blocks |
| Alarm 8-blocks | Yes |
| Number of instances for alarm 8 and S7 communication | 2 500 |
| | E 000 |

| blocks, max. | |
|---|--|
| • preset, max. | 900 |
| Process control messages | Yes |
| Number of archives that can log on simultaneously (SFB 37 AR_SEND) | 16 |
| Test commissioning functions | |
| Status block | Yes |
| Single step | Yes |
| Number of breakpoints | 16 |
| Status/control | |
| Status/control variable | Yes; Up to 16 variable tables |
| Variables | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters |
| Number of variables, max. | 70 |
| Forcing | |
| Forcing | Yes |
| Forcing, variables | Inputs/outputs, bit memories, distributed I/Os |
| Number of variables, max. | 256 |
| Diagnostic buffer | |
| • present | Yes |
| Number of entries, max. | 3 200 |
| — adjustable | Yes |
| — preset | 120 |
| Service data | |
| • can be read out | Yes |
| EMC | |
| Emission of radio interference acc. to EN 55 011 | |
| Limit class A, for use in industrial areas | Yes |
| Limit class B, for use in residential areas | No |
| configuration / header | |
| Configuration software | |
| • STEP 7 | Yes |
| - 0121 / | The state of the s |
| configuration / programming / header | |
| | see instruction list |
| configuration / programming / header | |
| configuration / programming / header • Command set • Nesting levels • Access to consistent data in process image | see instruction list |
| configuration / programming / header • Command set • Nesting levels | see instruction list |
| configuration / programming / header • Command set • Nesting levels • Access to consistent data in process image | see instruction list 7 Yes |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) | see instruction list 7 Yes see instruction list |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) | see instruction list 7 Yes see instruction list |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language | see instruction list 7 Yes see instruction list see instruction list |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL | see instruction list 7 Yes see instruction list see instruction list |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL | see instruction list 7 Yes see instruction list see instruction list Yes Yes |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously actives | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously actives RD_REC | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously actives RD_REC WR_REC | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active — RD_REC WR_REC WR_PARM | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active — RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes A See SFC / header 8 8 8 1 |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active — RP_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RD_REC RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDREC | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active — RP_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RRDREC WRREC WRREC | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes SFC / header 8 8 8 1 2 8 8 1 2 8 8 1 |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDREC WRREC WRREC Know-how protection User program protection/password protection | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes SFC / header 8 8 8 1 2 8 8 1 2 8 8 8 1 1 2 8 8 8 1 Yes Yes |
| configuration / programming / header Command set Nesting levels Access to consistent data in process image System functions (SFC) System function blocks (SFB) Programming language LAD FBD STL SCL CFC GRAPH HiGraph® configuration / programming / number of simultaneously active RD_REC WR_REC WR_PARM PARM_MOD WR_DPARM DPNRM_DG RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RDSYSST DP_TOPOL configuration / programming / number of simultaneously active RRDREC WRREC WRREC | see instruction list 7 Yes see instruction list see instruction list Yes Yes Yes Yes Yes Yes Yes Yes Yes Ye |

| Width | 50 mm |
|-----------------|--------|
| Height | 290 mm |
| Depth | 219 mm |
| Weights | |
| Weight, approx. | 995 g |

last modified: 4/1/2022 🖸