## **SIEMENS**

Data sheet 5SL6302-7



Miniature circuit breaker 400 V 6kA, 3-pole, C, 2A

Model	
product brand name	SENTRON
product designation	Miniature circuit breaker
General technical data	
number of poles	3
design of pole	3P
tripping characteristic class	С
mechanical service life (operating cycles) typical	10 000
overvoltage category	III
degree of pollution	2
Voltage	
type of voltage of the operating voltage	AC
insulation voltage (Ui)	
<ul> <li>with multi-phase operation at AC rated value</li> </ul>	440 V
Supply voltage	
supply voltage at AC rated value	400 V
value range of the supply voltage frequency	50/60 Hz
operating voltage	
<ul> <li>with multi-phase operation at AC maximum</li> </ul>	440 V
<ul> <li>at DC rated value maximum</li> </ul>	72 V
Protection class	
protection class IP	IP20, with connected conductors
Switching capacity	
switching capacity current	
<ul> <li>according to EN 60898 rated value</li> </ul>	6 kA
<ul> <li>according to IEC 60947-2 rated value</li> </ul>	6 kA
energy limitation class	3
Dissipation	
power loss [W] for rated value of the current at AC in hot operating state per pole	1.2 W
suitability for operation	Residential buildings/infrastructure
Product details	
product feature	
• halogen-free	Yes
• sealable	Yes
• silicon-free	Yes
product extension installable supplementary devices	Yes
Connections	
connectable conductor cross-section solid	

• maximum	25 mm²	
connectable conductor cross-section stranded		
• minimum	0.75 mm²	
• maximum	25 mm²	
connectable conductor cross-section finely stranded with core end processing		
• minimum	0.75 mm²	
• maximum	25 mm²	
tightening torque with screw-type terminals		
• minimum	2.5 N·m	
• maximum	3 N·m	
Mechanical Design		
height	90 mm	
width	54 mm	
depth	76 mm	
installation depth	70 mm	
number of modular width units	3	
mounting position	any	
net weight	360 g	
Environmental conditions		
ambient temperature during operation		
• minimum	-25 °C	
• maximum	45 °C	
ambient temperature during storage		
• minimum	-40 °C	
• maximum	75 °C	
General Product Approval		Declaration of Conformity

Declaration of Conformity other Environment



Confirmation Miscellaneous Environm

Environmental Confirmations

**TSE** 

## Further information

Siemens has decided to exit the Russian market (see here).

https://press.siemens.com/global/en/pressrelease/siemens-wind-down-russian-business

## Siemens is working on the renewal of the current EAC certificates.

Confirmation

Please contact your local Siemens office on the status of validity of the EAC certification if you intend to import or offer to supply these products to an EAC relevant market (other than the sanctioned EAEU member states Russia or Belarus).

## Information on the packaging

https://support.industry.siemens.com/cs/ww/en/view/109813875

Information- and Downloadcenter (Catalogs, Brochures,...)

http://www.siemens.com/lowvoltage/catalogs

Industry Mall (Online ordering system)

https://mall.industry.siemens.com/mall/en/en/Catalog/product?mlfb=5SL6302-7

Service&Support (Manuals, Certificates, Characteristics, FAQs,...)

https://support.industry.siemens.com/cs/ww/en/ps/5SL6302-7

Image database (product images, 2D dimension drawings, 3D models, device circuit diagrams, ...)


http://www.automation.siemens.com/bilddb/cax\_en.aspx?mlfb=5SL6302-7


**CAx-Online-Generator** 

http://www.siemens.com/cax

Tender specifications

http://www.siemens.com/specifications





last modified: 8/29/2023 🖸

5SL6	3027
Page	5/5